

VOC Content Test Certificate

Tuesday 25th October 2022

Supplier Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills, NSW 2147, Australia).

Sample Description Ardex WPM 265 22G01N

Date Tested October 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method ASTM D3960 & ASTM D2369 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred to in accordance with the laboratory testing guidance from the Green Building Council of Australia.

Test Results

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Ardex WPM 265 22G01N
Water Proofing Membrane and Sealants Limit: 250 grams per litre	9 grams per litre as VOC content per material
Meets GBCA VOC Content Requirement	Yes



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant



Dr. Tuan Duong
 PhD, BE (Chem. Eng.)
 Senior Consultant



Travis Hale
 BSc (Biotechnology)
 Senior Consultant

P22090047